

CERTIFICATE OF CONFORMITY

Product Certification Scheme: Class 1

This Certificate is issued to:

KYODO-ALLIED TECHNOLOGY PTE LTD
17 Kian Teck Road
Jurong Industries Estate
Singapore 628771

FOR

Product : *Fire Damper*
Brand : *Kyodo-Allied*
Model : *IBD-2 & IBD-2H*
Country of Origin : *Singapore*
Product Details : *Refer to appendix*

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS 333 : 2012
BS 476 Part 20: 1987

TEST REPORT(S)

WF 311603, WF 311606
WFRS Assess No. SC1461
BWA Review No. 23601-01
G61261/WCM, G41938/EMC
719165915-MEC-MW
719177393-MEC10-JC
EWA Report No. 26749-03
Report No. 30S-13-0176-TRP-342938-0



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Original Issue	Date of Last Revision	Date of Expiry
FSP-2011-0019	27/01/2011	12/05/2015	26/01/2017



This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at www.setsco.com.

APPENDIX TO CERTIFICATE NO. FSP-2011-0019

KYODO ALLIED TECHNOLOGY PTE LTD

Product Details:

Integrity: 240mins Vertical fire damper when installed on masonry wall for thickness up to 1500mm, Vertical and Horizontal fire damper Min size 100mm x 100mm to Max size 9608mm x 2760mm x (12 x 3)
Integrity: 120mins Vertical fire damper when installed on any type of drywall Max size: 1200mm x 1200mm, 7200mm x 1200mm (12 x 2), 10800mm x 2700mm (12 x 3), 10800mm x 1800mm (12 x 2)
Galvanized and stainless steel curtain type vertical and horizontal fire damper



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Original Issue	Date of Last Revision	Date of Expiry
FSP-2011-0019	27/01/2011	12/05/2015	26/01/2017

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.